



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088
Travelers Rest, SC 29690

Model No.

B-2339-7132MVBH

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



B-0963
1/2" NPT
Vacuum Breaker



HW-4B-24
3/8" NPT x 24" Flexible Water
Connector w/ Quick Disconnect

This Space for Architect/Engineer Approval


Job Name _____ Date _____

Model Specified _____ Quantity _____

Customer/Wholesaler _____

Contractor _____

Architect/Engineer _____



Cabinet Rough-In Requirement:
20 1/4" H x 14 1/4" W x 5" D

Product Specifications:

Open Hose Reel w/ 35' Hose, 1.42 GPM Spray Valve, Rinse Control Cabinet w/ Control Valve, Dual Check Valves, Thermometer, Water Hammer Arrestor, 1/2" NPT Vacuum Breaker & 3/8" Flexible Water Connector w/ Quick Disconnect

Product Compliance:

ASSE 1024 (VB)
NSF 61 Exempt (Non-Potable)
EPA 2005 Compliant (PRSV)