




FXCS Series - Seal-XM - Aluminum Dead-End Maintained Contact Push/Pull Mushroom- Red Button- 3/4" Hub- 1NO/1NC Contact Rating

By Killark
Catalog # [FXCS-2MMR3-M](#)



FXCS Series - Seal-XM - Aluminum Dead-End Maintained Contact Push/Pull Mushroom- Red Button- 3/4" Hub- 1NO/1NC Contact Rating.

Features

- Incorporates Factory Sealed Universal contact blocks and GOB3 LED pilot light devices.
- External sealing fittings typically not required, reducing installation time and cost.
- No seal plate between the electrical device and back box allows direct wiring to contact terminals.
- NEMA 3 weatherproof.
- Grounding boss supplied in the splice box.
- Sold as a complete unit.
- Standard finish is a gray epoxy powder baked on for ultimate corrosion resistance.
- More wiring room in back box.

Application

SEAL-XM Series is used to prevent the igniting of external hazardous atmospheres by the enclosed arcing devices in such areas as: hazardous locations due to the presence of flammable gases or vapors, combustible dusts or easily ignitable fibers or flyings

General

Action	Maintained
Actuator	Mushroom Pushbutton
Ambient Temp. Range	UL: -25 to 40 °C, CSA: -50 to 40 °C, IEC: -20 to 40 °C
Back Box Type	FXB
Color	<ul style="list-style-type: none"> • Red • Rouge
EU RoHS Indicator	Contact Manufacturer
Hub Pattern	Dead-End
Series	Seal-XM
Type	<ul style="list-style-type: none"> • Factory Sealed • Factory Sealed
UPC	783936002576

Dimensions

Depth	5.59
Hub Size	3/4"

Electrical Ratings

Amperage Rating	10 A
Frequency Rating	50/60 Hz

Certifications and Compliance

CSA File Number	LR11714, 2493125
Hazardous Rating(s)	<ul style="list-style-type: none"> • Class I, Divisions 1 & 2, Groups C, D • Class I, Zones 1 & 2, Groups IIB, IIA • Class II, Divisions 1 & 2, Groups E, F, G • Class III, Divisions 1 & 2

Nema Rating	3
-------------	---

Logistics

Factory Sealed	Factory Sealed
----------------	----------------

Product Assets

- [Catalogs - Killark Catalog](#)
- [Certifications - FXCS Series Factory Sealed Control Stations](#)
- [CSA Certification](#)
- [Certifications - FXCS & XCS Series Auxiliary Devices UL Certification](#)
- [Customer Notices - Prop 65 Notice](#)
- [Installation Manuals - FXCS Seal-XM IOM K1390](#)



A proud member of the Hubbell Family.

