

# Installation

## GATEWAY POWER SUPPLY

- Mount to any junction box through a 1/2" knockout (note: chase nipple is long enough to accommodate mounting inside an adjacent box if necessary)
- Connect unit's Class 1 wires to line voltage feed
- Interconnect unit (via RJ-45 ports) with Gateway or other nLight devices in lighting zone using CAT-5 cables

